

A M E N D E D**APPLICATION FOR PERMIT
TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA**Date of filing in State Engineer's Office OCT 26 2005Returned to applicant for correction NOV 15 2005Corrected application filed JAN 13 2006Map filed SEP 09 1999 under 65484

The applicant **Republic Silver State Disposal, Inc.** hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. **See attached Doc #1 Articles of Incorporation Document # C14710-1997-001 File Date 07/09/1997 Corporation Trust Company of Nevada 1 East First St., Reno, Nevada 89501**

1. The source of the proposed appropriation is **underground**
- 2 The amount of water applied for is **50 AFA (New) 1.0 second-feet**
 - (a) If stored in reservoir give number of acre-feet **N/A**
- 3 The water to be used for **Commercial (see attached)**
- 4 If use is for:
 - (a) Irrigation, state number of acres to be irrigated **N/A**
 - (b) Stockwater, state number and kinds of animals to be watered **N/A**
 - (c) Other use (describe fully under No. 12. "Remarks")
 - (d) Power:
 - (1) Horsepower developed **N/A**
 - (2) Point of return of water to stream **N/A**
- 5 The water is to be diverted from its source at the following point **NE¹/₄ SW¹/₄ of Section 19, T23S, R.61E., MDM or at a point whence the C¹/₄ corner of said Section 19 bears N. 27 43' 40 E. a distance of 490 ft.**
- 6 Place of Use **portion of E¹/₂ NE¹/₄ SW¹/₄ Sec 19 T23S R61E, M.D.B.&M. APN # 191-19-301-013**
7. Use will begin about **Jan 1** and end about **Dec 31** of each year.
- 8 Description of proposed works **well with pump and motor existing**
9. Estimated cost of works **(n/a) existing**
10. Estimated time required to construct works **(n/a) existing**
11. Estimated time required to complete the application of water to beneficial use **12 months**

73389

12. Remarks: See map on file 65484

By s/ Alan J. Gaddy
770 E. Sahara Ave
Las Vegas Nev., 89104

Compared gkl/ SC

Protested _____

DENIAL OF STATE ENGINEER

The application is hereby denied on the grounds that its approval would conflict with previous rulings and existing water rights and threaten to prove detrimental to the public interest.

IN TESTIMONY WHEREOF, I, TRACY TAYLOR, P.E.,

State Engineer of Nevada, have hereunto set

my hand and the seal of my office,

this 27th day of June, A.D. 2008

Tracy Taylor P.E.
State Engineer

Fixture Count
Water Usage Justification

Listed are the number of fixtures and sizes of outlets.

1. Eight (8) Toilets
2. Two (2) Urinals
3. Six (6) Sinks
4. Two (2) Drinking Fountains
5. Two (2) Ice Machines
6. Four (4) 1" Hose outlets
7. One (1) 2" Supply to Misters (dust control)
8. Six (6) 1 ½ " Hose outlets on Station Floor
9. One (1) 1 ½ " Hose outlet In Transfer Truck Tunnel
10. Fire Suppression System is also supplied by same water system.

The mister system is supplied on the average of 10 hours a day seven days a week. We approximate the water usage to be at four hundred sixteen Thousand (416,000) gallons per year. The 1 ½" hoses are used for fire suppression and added dust control when needed. These can produce approximately 100 gpm.